

## Wedi Systems (UK) Ltd

Unit 4 Mercury Park  
Mercury Way  
Trafford Park  
Manchester M41 7LY

Tel: 0161 864 2336

e-mail: [technical@wedi.co.uk](mailto:technical@wedi.co.uk)

website: [www.wedi.co.uk](http://www.wedi.co.uk)



## Agrément Certificate

14/5126

Product Sheet 1 Issue 3

### WEDI SHOWER ELEMENTS

### WEDI FUNDO SHOWER TRAYS

This Agrément Certificate Product Sheet<sup>(1)</sup> relates to wedi<sup>(2)</sup> Fundo Shower Trays, a range of shower trays for use in tiled floor-level built-in shower systems in private residential and public buildings.

(1) Hereinafter referred to as 'Certificate'.

(2) 'wedi' is a registered trademark.

#### The assessment includes

##### Product factors:

- compliance with Building Regulations
- compliance with additional regulatory or non-regulatory information where applicable
- evaluation against technical specifications
- assessment criteria and technical investigations
- uses and design considerations

##### Process factors:

- compliance with Scheme requirements
- installation, delivery, handling and storage
- production and quality controls
- maintenance and repair

##### Ongoing contractual Scheme elements†:

- regular assessment of production
- formal 3-yearly review



#### KEY FACTORS ASSESSED

- Section 1. Mechanical resistance and stability
- Section 2. Safety in case of fire
- Section 3. Hygiene, health and the environment
- Section 4. Safety and accessibility in use
- Section 5. Protection against noise
- Section 6. Energy economy and heat retention
- Section 7. Sustainable use of natural resources
- Section 8. Durability

The BBA has awarded this Certificate to the company named above for the products described herein. These products have been assessed by the BBA as being fit for their intended use provided they are installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Date of Third issue: 25 November 2024

Originally certified on 06 June 2014

Hardy Giesler  
Chief Executive Officer

*This BBA Agrément Certificate is issued under the BBA's Inspection Body accreditation to ISO/IEC 17020. Sections marked with † are not issued under accreditation.*

*The BBA is a UKAS accredited Inspection Body (No. 4345), Certification Body (No. 0113) and Testing Laboratory (No. 0357).*

*Readers MUST check that this is the latest issue of this Agrément Certificate by either referring to the BBA website or contacting the BBA directly.*

*The Certificate should be read in full as it may be misleading to read clauses in isolation.*

*Any photographs are for illustrative purposes only, do not constitute advice and should not be relied upon.*

#### British Board of Agrément

1<sup>st</sup> Floor, Building 3, Hatters Lane  
Croxley Park, Watford  
Herts WD18 8YG

©2024

tel: 01923 665300  
[clientservices@bbacerts.co.uk](mailto:clientservices@bbacerts.co.uk)  
[www.bbacerts.co.uk](http://www.bbacerts.co.uk)

## SUMMARY OF ASSESSMENT AND COMPLIANCE

This section provides a summary of the assessment conclusions; readers should refer to the later sections of this Certificate for information about the assessments carried out.

### Compliance with Regulations

Having assessed the key factors, the opinion of the BBA is that wedi Fundo Shower Trays, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations:



#### The Building Regulations 2010 (England and Wales) (as amended)

<b>Requirement:</b>	<b>C2(d)</b>	<b>Resistance to moisture</b>
Comment:		The products will contribute to satisfying this Requirement. See section 3 of this Certificate.
<b>Requirement:</b>	<b>M1</b>	<b>Access to and use of buildings other than dwellings</b>
Comment:		The products can contribute to satisfying this Requirement. See section 4 of this Certificate.
<b>Requirement:</b>	<b>M4(1)</b>	<b>Access and use</b>
Comment:		The products can contribute to satisfying this Requirement. See section 4 of this Certificate.
<b>Regulation:</b>	<b>7(1)</b>	<b>Materials and workmanship</b>
Comment:		The products are acceptable. See sections 8 and 9 of this Certificate.



#### The Building (Scotland) Regulations 2004 (as amended)

<b>Regulation:</b>	<b>8(1)(2)</b>	<b>Fitness and durability of materials and workmanship</b>
Comment:		The products are acceptable. See sections 8 and 9 of this Certificate.
<b>Regulation:</b>	<b>9</b>	<b>Building standards – construction</b>
Standard:	3.12	Sanitary facilities
Comment:		The use of the products is restricted by this Standard, with reference to clauses 3.12.4 <sup>(1)</sup> and 3.2.10 <sup>(2)</sup> . See section 4 of this Certificate.
Standard:	7.1(a)	Statement of sustainability
Comment:		The products can contribute to satisfying the relevant requirements of Regulation 9, Standards 1 to 6, and therefore will contribute to a construction meeting a bronze level of sustainability as defined in this Standard.
<b>Regulation:</b>	<b>12</b>	<b>Building standards – conversion</b>
Comment:		Comments in relation to the products under Regulation 9, Standards 1 to 6, also apply to this Regulation, with reference to clause 0.12.1 <sup>(1)(2)</sup> and Schedule 6 <sup>(1)(2)</sup> .
		(1) Technical Handbook (Domestic).
		(2) Technical Handbook (Non-Domestic).



#### The Building Regulations (Northern Ireland) 2012 (as amended)

<b>Regulation:</b>	<b>23(1)(a)(i)</b>	<b>Fitness of materials and workmanship</b>
Comment:	<b>(iii)(b)(i)</b>	The products are acceptable. See sections 8 and 9 of this Certificate.
<b>Regulation:</b>	<b>86(1)</b>	<b>Sanitary appliances</b>
Comment:		The products can contribute to satisfying this Regulation. See section 4 of this Certificate.

## Additional Information

### NHBC Standards 2024

In the opinion of the BBA, wedi Fundo Shower Trays, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements in relation to *NHBC Standards*, Chapter 8.1 *Internal Services*.

## Fulfilment of Requirements

The BBA has judged wedi Fundo Shower Trays to be satisfactory for use as described in this Certificate. The products have been assessed for use in tiled floor-level built-in shower systems in private residential and public buildings.

## ASSESSMENT

### Product description and intended use

The Certificate holder provided the following description for the products under assessment.

wedi Fundo Shower Trays are a range of shower trays, consisting of a proprietary rigid extruded polystyrene core coated on both faces with a polymer-modified cementitious coating reinforced with a glass fibre mesh. Each shower element is manufactured with falls towards the drain outlet. The shower trays are available in the range of shapes and standard sizes detailed in Table 1. Other sizes are available by special order.

#### Ancillary Items

The following ancillary items are essential to use with the products and have been assessed with the products:

- wedi construction panel / wedi Fundo sealing system (the subject of UKTA-0836-23/6937), referenced in the UKTA as 'watertight kit'
- wedi 610 adhesive sealant — a one-component, moisture-cured elastomeric adhesive for sealing joints between the shower trays and wedi Building Boards
- wedi 520 membrane adhesive — a two-component flexible waterproofing compound used in conjunction with wedi sealing tape to waterproof joints between the shower elements and wedi building boards
- wedi building boards — rigid extruded polystyrene foam boards, finished on both sides with a polymer-modified cement coating reinforced with a glass fibre mesh (the subject of BBA Certificate 00/3675)
- wedi sealing tape — used in conjunction with wedi 610 adhesive sealant or wedi 520 membrane adhesive to seal joints between the shower trays and wedi building boards
- wedi self-adhesive reinforcement tape — used over joints in dry areas
- Fundo sealing sets [includes wedi 520 membrane adhesive, wedi sealing tape (10 m), and 2 x internal corners].

The Certificate holder recommends the following ancillary items for use with the products, but these materials have not been assessed by the BBA and are outside the scope of this Certificate:

- flexible waterproof tile adhesive conforming to BS EN 12004 : 2007
- flexible waterproof grout conforming to BS EN 13888 : 2009
- suitable floor tiles
- wedi Fundo drain elements
- wedi sealing corners
- wedi edge strip
- sound impact deadening boards
- sloping boards
- wedi Fundo easy sets to aid installation.

The products are intended for use:

- in tiled floor-level built-in shower systems in domestic and public buildings
- as built-in shower trays fully supported on stable timber or concrete floors
- in domestic and public buildings and in installations designed in accordance with BS EN 12056-1 : 2000 and BS EN 12056-2 : 2000.

**Table 1 Product range**

Name	Shape / size (mm)		
	Square		Rectangle
Fundo Primo <sup>(1)</sup>	900 x 900 x 40		900 x 750 x 40
	1000 x 1000 x 40		1200 x 900 x 40
	1200 x 1200 x 40		1400 x 900 x 40
	1500 x 1500 x 40		1400 x 1000 x 40
Fundo Ligno <sup>(1)(9)</sup>	900 x 900 x 20	1500 x 1500 x 20	1200 x 900 x 20
	1200 x 1200 x 20		1600 x 900 x 20
Fundo Riofino <sup>(4)</sup>	900 x 900 x 50	1200 x 1200 x 50	1200 x 900 x 50
	1000 x 1000 x 50		1800 x 900 x 50
Fundo Riolito <sup>(5)</sup>	900 x 900 x 50		1200 x 900 x 50
	1200 x 1200 x 50		1200 x 1000 x 50
Fundo Riolito Neo <sup>(5)</sup>	900 x 900 x 50		1200 x 800 x 50
	1000 x 1000 x 50		1200 x 900 x 50
	1200 x 1200 x 50		1200 x 1000 x 50
Fundo Plano complete system <sup>(1)(6)</sup>	900 x 900 x 65	1200 x 1200 x 65	1200 x 900 x 65
	1000 x 1000 x 65		1400 x 900 x 65
Fundo Plano Linea complete system <sup>(5)(6)</sup>	900 x 900 x 70		1200 x 800 x 70
			1200 x 900 x 70
Fundo Integro complete system <sup>(1)(6)</sup>	900 x 900 x 90		1200 x 900 x 90
	1200 x 1200 x 90		1400 x 900 x 90
Sloping Boards Primo			600 x 1200 x 40-46
			600 x 1200 x 46-52
Sloping Board Riolito Neo, Riolito, Riofino			600 x 1200 x 50-60
Discreto Riolito Neo, Riolito <sup>(7)</sup>			800 x 180 x 76
			900 x 180 x 76
Fundo Borgo <sup>(3)(8)</sup>	900 x 900 x 40	1000 x 1000 x 40	
Fundo Trollo <sup>(2)</sup>			Circular 1140 x 40
Fundo Nautilo <sup>(2)(8)</sup>			Nautilus spiral 1890 x 1515

(1) Round drain – central/offset

(2) Round drain – central

(3) Round drain – offset

(4) Channel drain – central

(5) Channel drain – lateral

(6) with integrated drain

(7) attachment wall element

(8) fits in square and rectangle shape

(9) with tapered edge

## Product assessment – key factors

The products were assessed for the following key factors, and the outcome of the assessments is shown below. Conclusions relating to the Building Regulations apply to the whole of the UK unless otherwise stated.

### 1 Mechanical resistance and stability

Data were assessed for the following characteristics.

#### 1.1 Behaviour under loading

1.1.1 Results of dynamic loading test are shown in Table 2.

**Table 2 Characteristics of loading**

Product assessed	Assessment method	Requirement	Result
Shower tray	Dynamic loading and leak tightness to BBA Method	No damage and leakage	Pass
wedi construction panel / wedi Fundo sealing watertight kit	Dimensional stability <sup>(1)</sup> to ETAG 022-3 : 2002	Longitudinal and transversal direction < ± 0.1 %, thickness < ± 5 %	Pass

(1) An assessment was made (leading to the issue of UKTA-0836-23/6937 in accordance with UKAD 030437-00-0503) of test results relating to the wedi Watertight Kit for wet room floors and walls based on watertight boards, including wedi Fundo

1.1.2 On the basis of data assessed, the products are deemed to be sufficiently resistant to compression and capable of resisting the uniformly distributed loads likely to be experienced in service with minimal deflection.

1.1.3 The level of resistance to concentrated loads will depend on the size and strength of the tiles used and must be carefully considered, especially in special cases, eg when wheelchair access is required.

## 2 Safety in case of fire

Not applicable.

## 3 Hygiene, health and the environment

### 3.1 Hygiene, health and the environment

3.1.1 Results of hygiene tests are given in Table 3.

**Table 3 Resistance tests**

Product assessed	Assessment method	Requirement	Result
wedi construction panel / wedi Fundo sealing watertight kit	Resistance to temperature, water and alkalinity <sup>(1)</sup> to ETAG 022-3 : 2002	Category 2: ≥ 0.5 MPa	Pass
	Watertightness <sup>(1)</sup> to ETAG 022-3 : 2002	Category 2: Watertight	Pass
	Crack Bridging ability <sup>(1)</sup> to ETAG 022-3 : 2002	Category 1: 0.4 mm	Pass
	Bond strength <sup>(1)</sup> to ETAG 022-3 : 2002	Category 1: ≥ 0.2 MPa Category 2: ≥ 0.3 MPa	Pass
Shower drains	Head of water test to BBA Method	No leakage	Pass

(1) An assessment was made (leading to the issue of UKTA-0836-23/6937 in accordance with UKAD 030437-00-0503) of test results relating to the wedi Watertight Kit for wet room floors and walls based on watertight boards, including wedi Fundo

3.1.2 On the basis of data assessed, the shower elements are deemed suitable to be used as part of a system to provide a waterproof shower enclosure.

3.1.3 The shower drains, when installed in accordance with the Certificate holder's instructions, will form a watertight seal to shower elements.

## 4 Safety and accessibility in use

### 4.1 Accessibility in use

4.1.1 Installations of the products can be designed to provide step-free access to shower facilities and facilitate access, eg by wheelchairs.

4.1.2 The products are manufactured with designed falls to the outlet to ensure efficient drainage. Care must be taken to retain the falls when fixing the elements and after tiling.

## 5 Protection against noise

Not applicable.

## 6 Energy economy and heat retention

Not applicable.

## 7 Sustainable use of natural resources

The products are manufactured from polystyrene, which can be recycled.

## 8 Durability

8.1 The potential mechanisms for degradation and the known performance characteristics of the materials in these products were not assessed.

### 8.2 Service life

Under normal service conditions, the products will have a life of at least 10 years, provided they are designed, installed and maintained in accordance with this Certificate and the Certificate holder's instructions.

## PROCESS ASSESSMENT

Information provided by the Certificate holder was assessed for the following factors:

## 9 Design, installation, workmanship and maintenance

### 9.1 Design

Not applicable.

### 9.2 Installation

9.2.1 Installation instructions provided by the Certificate holder were assessed and judged to be appropriate and adequate.

9.2.2 Installation must be carried out in accordance with this Certificate and the Certificate holder's instructions. A summary of instructions and guidance is provided in Annex A.

9.2.3 The shower elements must be installed fully supported on a stable substrate in accordance with the Certificate holder's installation instructions and this Certificate.

9.2.4 Existing floors must be in a good condition. Damaged joists in wooden floors must be repaired or replaced prior to installing the products.

9.2.5 The products must be fully bonded to the substrate using a flexible cementitious tile adhesive approved by the Certificate holder, and in accordance with the adhesive manufacturer's instructions for mixing and use.

9.2.6 All joints must be sealed and taped with wedi 610 Adhesive Sealant and wedi Self-Adhesive Reinforcement Tape. In wet areas, joints must be sealed with wedi 610 Adhesive Sealant and wedi Sealing Tape, or wedi 520 Membrane Adhesive and wedi Sealing Tape.

9.2.7 Only wedi Fundo Drain Elements must be used with the products, and must be fixed in accordance with the Certificate holder's instructions.

9.2.8 The products must be finished with non-slip tiles. The Certificate holder must be consulted for suitable products.

9.2.9 Drainage pipes must be carefully positioned and correctly sized to accept the outlet pipe from the drain element. Reference should be made to BS EN 12056-1 : 2000 and BS EN 12056-2 : 2000, and any special requirements for the drain used.

### 9.3 Workmanship

Practicability of installation was assessed by the BBA, on the basis of the Certificate holder's information and a site visit to witness an installation in progress. To achieve the performance described in this Certificate, installation of the products must be carried out by a competent general builder, or a contractor, experienced with these types of products.

### 9.4 Maintenance and repair

9.4.1 Ongoing satisfactory performance of the products in use requires regular maintenance. The guidance provided by the Certificate holder was assessed by the BBA and found to be appropriate and adequate.

The following requirements apply in order to satisfy the performance assessed in this Certificate:

9.4.2 The surface of the products must be cleaned and drain traps must be regularly cleared of obstructions to ensure satisfactory drainage.

## **10 Manufacture**

10.1 The production processes for the products have been assessed, and provide assurance that the quality controls are satisfactory according to the following factors:

10.1.1 The manufacturer has provided documented information on the materials, processes, testing and control factors.

10.1.2 The quality control operated over batches of incoming materials has been assessed and deemed appropriate and adequate.

10.1.3 The quality control procedures and product testing to be undertaken have been assessed and deemed appropriate and adequate.

10.1.4 The process for management of non-conformities has been assessed and deemed appropriate and adequate.

10.1.5 An audit of each production location was undertaken, and it was confirmed that the production process was in accordance with the documented process, and that equipment has been properly tested and calibrated.

†10.2 The BBA has undertaken to review the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.

## **11 Delivery and site handling**

11.1 The Certificate holder stated that the products are delivered to site as follows:

- shower elements are packed individually in cardboard boxes. The products must be stored flat, under cover and protected from heat sources, direct sunlight and moisture.
- sealant is supplied in 310 ml plastic cartridges and the adhesive membrane is supplied as two components, a powder component and a liquid component. The powder is supplied in 20 kg paper sacks and the liquid in 10 litre plastic containers.
- sealing tape is available in rolls of 10 m x 120 mm and 50 mm x 120 mm, and the reinforcement tape is available in rolls of 25 m x 125 mm and 50 m x 600 mm.

11.2 Delivery and site handling must be performed in accordance with the Certificate holder's instructions and this Certificate, including:

11.2.1 Requirements for transportation on site, storage and lifting of components must be in accordance with PD CEN/TR 13801 : 2014.

11.2.2 The products should be transported in their original packaging if possible. During unloading they must be handled with care. The products must not be dragged across the floor or pulled over edges.

11.2.3 Care must be taken not to drop products on their edges.

11.2.4 The products must be stored flat, under cover and protected from heat sources, direct sunlight and moisture.



Supporting information in this Annex is relevant to the products but has not formed part of the material assessed for the Certificate.

### Construction (Design and Management) Regulations 2015

### Construction (Design and Management) Regulations (Northern Ireland) 2016

Information in this Certificate may assist the client, designer (including Principal Designer) and contractor (including Principal Contractor) to address their obligations under these Regulations.

### CPL Regulations

The Certificate holder has taken the responsibility of classifying and labelling the products and/or components under the *GB CLP Regulation* and *CLP Regulation (EC) No 1272/2008 - classification, labelling and packaging of substances and mixtures*. Users must refer to the relevant Safety Data Sheet(s).

### UKCA marking

The Certificate holder has taken the responsibility of UKCA marking the product in accordance with UKAD 030437-00-0503.

### CE marking

The Certificate holder has taken the responsibility of CE marking the products, in accordance with EAD 090010-00-0404 : 2018<sup>(1)</sup>.

(1) EAD 090010-00-0404 : 2018 replaced ETAG 002 : 2002 Part 3.

### Management Systems Certification for production

The management system of the manufacturer has been assessed and registered as meeting the requirements of ISO 9001 : 2015, 14001 : 2015 and ISO 50001 : 2018 by Gutcert (Certificate Q-22-23254-EN, U-21-23254-EN and B-22-23254-EN respectively).

### Additional information on installation

Installation must be in accordance with the Certificate holder's instructions and this Certificate.

A.1 The lower part of the drain element, with the appropriate length of connecting pipe, is positioned in a made-to-size recess and connected to the existing drainage pipe. Care must be taken to ensure that the necessary distance between the drain flange and surrounding screed is correct.

A.6 The recess is filled with a suitable mortar and finished at the required height. The drain element must be protected during this operation by inserting the protective cap tool.

A.7 Before the infill mortar has set, the drain protection cap is removed, and the products are carefully and loosely placed to check the correct positioning of the drain. If necessary, the position of the drain must be adjusted before the mortar sets.

A.8 When the position of the drain is correct, and the infill mortar cured, the upper part of the drain element is fixed to the shower tray in accordance with the Certificate holder's instructions.

A.9 The bottom face of the shower tray is fully coated with a cement-based flexible tile adhesive and combed with a middle-sized bed trowel.

A.10 The shower tray is positioned over the prepared recess so that the main sealing collar is located, and pressed exactly into the drain body, ensuring that the tray is horizontal in all directions to retain the built-in falls.

A.11 The plastic frame to receive the drain grid is bonded into the shower tray using the tile adhesive. If necessary, the height of the grid frame extension collar can be adjusted to take account of the thickness of the tiles to be used.

A.12 The shower tray is tiled using an approved cement-based flexible tile adhesive, ensuring that the valleys of the shower tray are reflected on the grout line to retain the built-in falls for drainage. This is particularly important when using tiles larger than 10 x 10 cm.

## Bibliography

BS EN 12004 : 2007 *Adhesives for tiles — Requirements, evaluation of conformity, classification and designation*

BS EN 12056-1 : 2000 *Gravity drainage systems inside buildings — General and performance requirements*

BS EN 12056-2 : 2000 *Gravity drainage systems inside buildings — Sanitary pipework, layout and calculation*

BS EN 13888 : 2009 *Grout for tiles — Requirements, evaluation of conformity, classification and designation*

EAD 030437-00-0503 : 2019 *Watertight covering kits based on inherently watertight boards for wet room floors and/or walls*

EAD 090010-00-0404 : 2018 *Bonded glazing kits and bonding sealants*

ETAG 002 : 2002 *Structural sealant glazing systems - Part 3 : Systems incorporating profiles with thermal barrier*

ETAG 022-3 : 2010 *Watertight covering kits for wet room floors and or walls - Part 3: Kits based on inherently watertight boards*

ISO 9001 : 2015 *Quality management systems — Requirements*

ISO 14001 : 2015 *Environmental management systems. Requirements with guidance for use*

ISO 50001 : 2018 *Energy management systems. Requirements with guidance for use*

PD CEN/TR 13801 : 2014 *Plastics piping systems for soil and waste discharge (low and high temperature) within the building structure — Thermoplastics — Recommended practice for installation*

## Conditions of Certificate

### Conditions

1 This Certificate:

- relates only to the product that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page – no other company, firm, organisation or person may hold or claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document – it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

3 This Certificate will be displayed on the BBA website, and the Certificate Holder is entitled to use the Certificate and Certificate logo, provided that the product and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

5 In issuing this Certificate the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product or any other product
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product
- actual installations of the product, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product, including its manufacture, supply, installation, use, maintenance and removal
- any claims by the manufacturer relating to UKCA marking and CE marking.

6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product which is contained or referred to in this Certificate is the minimum required to be met when the product is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.

### British Board of Agrément

1<sup>st</sup> Floor, Building 3, Hatters Lane  
Croxley Park, Watford  
Herts WD18 8YG

©2024

tel: 01923 665300  
clientservices@bbacerts.co.uk  
[www.bbacerts.co.uk](http://www.bbacerts.co.uk)